



[1]

Supplement No:1 Certificate of Conformity to Ex

[2] Ex Certificate Of Compliance Number : **IEP 13 EX 0142**

[3] Equipment : **FYRQ-01 Type Spill Container**

[4] Manufacturer : **Shanghai AILE Petroleum Equipment Mfg. Co. Ltd.**

[5] Address : **No:888 Chengliu Mid Rd. Jiading District Shanghai - CHINA**

[6] This equipment any of acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

[7] The IEP Uluslar Arası Enerji Petrol Gözetim , Sertifikasyon ve Teknik Hizmetler Organizasyonu Tic. Ltd. Sti. , Inspection Body Accreditation number AB-0097-M in accordance with TS EN ISO/IEC 17020 within the scope given in Annex following the assesment conducted by TURKAK . The examination and test results are recorded in confidential Report N : IEP - RP.Ex - 10. 492-1 date 22.08.2014


[8] Compliance with Essential Health and safety requirements has been assured by compliance with ;

EN 13463-1:2009 , EN 13463-5 :2011

[9] This Ex Certificate of Compliance relates only to the design examination and testing of the specified equipment in accordance to the standards.

[10] Manufacturer listed in the certificate is responsible for product conformity assurance in accordance with its specification (documentation) listed in Annex of the certificate and for successful performance of all specified routine tests and verification.

[11] The marking of the equipment or protective system shall include the following :




[12] This certificate is valid till : **19.06.2018**

Responsible person :

Nurettin Terzioglu
Head of certification body

Date of issue : 25.08.2014





[13] Report Nr : IEP - RP.Ex -10. 492-1

Report Date : 22.08.2014

[14] Description of Equipment

FYRQ-01 type spill container is designed for preventing fuel leakage which is convenient for transmission working between tank truck and storage. FYRQ-01 type spill container made from cover : cost iron / Al , corrugated pipe :PE Cover seat : cost iron , Chasis : composit material and steel therad ring , release valve PA 66 . Diameter 4" . 1 mounting manual date 22.12.2011 [2 pages]

Spill container is suitable for human traffic and smoll vehicle.

Chemical specifications of the parts attached . Atch. Table 1 Date 12.01.2012

Technical specifications :

Product Type : FYRQ-01 spill container

Diameter : 4" NPT

Standart type :

Inlet dimension : 360 mm

Depth dimension : 477,5 mm

Cover dimension : 403 mm

[15] Essential health and safety requirements : They are included in above mentioned standards of this certificate. The product was approved in accordance with according standards and manufacturer instruction.

[16] FYRQ-01 type spill container mounting manual date 22.12.2011 [2 pages]

[17] This certificate is in the contents of standarts that mentioned in item [8] It has been accepted that . FYRQ-01 type spill container are manufactured according to the producer instructions and the standards mentioned above.

[18] To was examined the due for the standard change .

Responsible person :

Date of issue : 25.08.2014

Nurettin Terzioğlu
Head of certification body

